

Certificate of Assessment

Job No.: NK7326

No. 2189

"Copyright CSIRO 2015 ©"
Copying or alteration of this report
without written authorisation from CSIRO is forbidden.

This is to certify that the specimen described below was tested by the CSIRO Infrastructure Technologies in accordance with Australian/ New Zealand Standard 3837, Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter, 1998, at 50 kW/m², on behalf of:

Borg Manufacturing Pty Ltd
1090 Pacific Highway
SOMERSBY NSW
AUSTRALIA

A full description of the test specimen and the complete test results are detailed in the Division's sponsored investigation report numbered FNK 11374.

SAMPLE

IDENTIFICATION: Polytec Compact Laminates

DESCRIPTION OF

SAMPLE: The sponsor described the tested specimen as a high-pressure laminate comprising kraft paper impregnated with phenol formaldehyde resin faced on both sides with decorative paper impregnated with melamine formaldehyde resin.

Nominal total thickness: 10 mm
Nominal density: 1400 kg/m³
Colour: light grey


SAMPLE

CLASSIFICATION: Group Number: Group 3
(In accordance with Specification A2.4 of the Building Code of Australia.)

Average specific extinction area: 197.4 m²/kg
(Refer to Specification C1.10 section 4(c) of the Building Code of Australia.)

Testing Officer: Heherson Alarde Date of Test: 9 September 2009

Issued on the 25th day of March 2015 without alterations or additions.



Brett Roddy
Team Leader, Fire Testing and Assessments



NATA Accredited Laboratory
Number: 165
Corporate Site No 3625
Accredited for compliance with ISO/IEC 17025.

CSIRO INFRASTRUCTURE TECHNOLOGIES

14 Julius Avenue, Riverside Corporate Park, North Ryde NSW 2113 AUSTRALIA
Telephone: 61 2 9490 5444 Facsimile: 61 2 9490 5555 www.csiro.au

