

AWTA PRODUCT TESTING

A Division of Australian Wool Testing Authority Limited

Laboratory: 1st Floor, 191 Racecourse Rd, Flemington, Victoria 3031 P.O. Box 240 Nth Melbourne 3051 Tel: (03) 9371 2400 Fax: (03) 9371 2499
Website: www.awtaproducttesting.com.au Email: producttesting@awta.com.au

A.B.N. 43 006 014 106

Group Number Assessment (in accordance with C/VM2 Appendix A Verification Method: Framework for Fire Safety Design For New Zealand Building Code Clauses C1-C6 Protection from Fire)

This is to confirm that the product as described below has been tested by AWTA Product Testing.

Testing was performed in accordance with ISO 5660.1:2015 Reaction to fire tests – Heat release, smoke production and mass loss rate – Part 1: Heat release rate (cone calorimeter method) and smoke production rate (dynamic measurement)

AWTA Product Testing report number: 19-001020

Date of Test: 12 April 2019

Test Sponsor

Borg Manufacturing Pty Ltd
2 Wella Way
Somersby NSW
2250

Sponsor Product Reference: "IMI Beton"

Sponsor Product Description: Concrete coated onto high-pressure laminate adhered to MDF
Colour: Grey Face
Nominal Mass: 45kg/m²
Nominal Thickness: 4.5mm
End Use: Internal walls and ceiling linings

Product Group Number Classification: Group 1S
Average Specific Extinction Area: 16.5 m²/kg



Chris Campbell
Client Relations Manager

The message/document(s) contained in this electronic attachment is intended for the party to which it is addressed and may contain confidential information or be subject to professional privilege. Its transmission is not intended to place the contents into the public domain.

If you have received this transmission in error, its disclosure or copying is prohibited. Please contact us by collect call so that arrangements can be made at our expense to rectify the error.