

Emission Test Certificate

Tuesday 22nd August 2023

Supplier: Borg Manufacturing Pty Ltd (2 Wella Way, Somersby, NSW, 2250, Australia)

Sample Description: Polytec Ultraglaze panel.

Date Tested: August 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (7 days):

Green Building Council of Australia Green Star Design & As Built V1.3 - 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.2	Polytec Ultraglaze
Total Volatile Organic Compound Emission Rate Limit: ≤0.500 mg/m ² /hr	Total Volatile Organic Compound Emission Rate: 0.014 mg/m ² /hr



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant



Dr. Tuan Duong
PhD, B.Eng. (Chemical)
Senior Consultant

Issued date: 22/8/2023

Expiry date: 22/8/2028

P23070097