

# VOC Emission Test Certificate

Friday 06<sup>th</sup> August 2021

Supplier: Borg Manufacturing (2 Wella Way, Somersby, 2250, NSW, Australia)

Sample Description: Polytec Createc-Venette (MDF-E0) Panel

Date Tested: August 2021 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (7 days):

|   |  |
|---|--|
| <p align="center"><b>Green Building Council of Australia</b><br/><b>Green Star Design &amp; As Built V1.3 - 13.1.2B &amp; 13.2</b><br/><b>Green Star Interiors V1.3 - 12.1.2B</b></p> | <p align="center"><b>Polytec Createc-Venette</b><br/><b>(MDF-E0) Panel</b></p>                     |
| <p align="center">Total Volatile Organic Compound Emission Rate Limit:<br/>≤0.500 mg/m<sup>2</sup>/hr</p>   | <p align="center">Total Volatile Organic Compound<br/>Emission Rate: 0.147 mg/m<sup>2</sup>/hr</p> |



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Travis Hale  
BSc (Biotechnology)  
Senior Consultant



Dr. Tuan Duong  
Ph.D, B.Eng. (Chemical)  
Senior Consultant

**V2107083**