

# VOC Emission Test Certificate

Monday 30<sup>th</sup> March 2026

Supplier: Porta Products Pty Ltd (2 Wella Way, Somersby, NSW, 2250, Australia).

Product Name: Polytec Xenolith.

Product Description: High pressure laminate comprising of layers of Kraft and Decorative papers impregnated with Melamine formaldehyde resin faced on both sides with decorative papers bonded together under heat and pressure

Date Tested: 24<sup>th</sup> March 2026 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116:2025 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

### Test Data (7 days):

<b>Specification</b> <b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3-13.1.1B</b> <b>Green Star Interiors V1.3-12.1.1B</b>	<b>Polytec Xenolith</b>
Total Volatile Organic Compound (C <sub>6</sub> -C <sub>16</sub> ) Emission Rate Limit: ≤0.500 mg/m <sup>2</sup> /hr	Total Volatile Organic Compound (C <sub>6</sub> -C <sub>16</sub> ) Emission Rate: 0.028 mg/m <sup>2</sup> /hr

Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

Dr. Tuan Duong  
PhD, BE (Chemical Engineer)  
Senior Consultant

Travis Hale  
BSc (Biotechnology)  
Senior Consultant